

## CAPITAL REGIONAL DISTRICT - INTEGRATED WATER SERVICES

### Water Watch for January 10, 2016

#### Water Supply System Summary:

##### 1. Useable Volume in Storage:

Reservoir	January 31 5 Year Ave		January 31/15		January 10/16		% Existing Full Storage
	ML	MIG	ML	MIG	ML	MIG	
Sooke	89,882	19,774	92,727	20,400	92,727	20,400	100.0%
Goldstream	8,864	1,950	8,523	1,875	8,040	1,769	81.8%
Total	98,746	21,724	101,250	22,275	100,767	22,169	98.3%

##### 2. Average Daily Demand:

For the month of January	95.5 MLD	21.02 MIGD
For week ending January 10, 2016	96.6 MLD	21.25 MIGD
Max. day January 2016, to date:	100.8 MLD	22.18 MIGD

##### 3. Average 5 Year Daily Demand for January

Average (2011 - 2015)	98.3 MLD <sup>1</sup>	21.63 MIGD <sup>2</sup>
-----------------------	-----------------------	-------------------------

<sup>1</sup>MLD = Million Litres Per Day      <sup>2</sup>MIGD = Million Imperial Gallons Per Day

##### 4. Rainfall January:

Average (1914 - 2015):	272.0 mm
Actual Rainfall to Date	2.5 (1% of monthly average)

##### 5. Rainfall: Sep 1 - Jan 10

Average (1914 - 2015):	874.9 mm
2015/2016	965.3 (110% of average)

##### 6. Water Conservation Action Required:

To avoid possible leaks next spring, now is the time to winterize your sprinkler system.

Check our website at [www.crd.bc.ca/water](http://www.crd.bc.ca/water) for more information.

If you require further information, please contact:

Ted Robbins, B.Sc., C.Tech  
General Manager, CRD - Integrated Water Services  
or

Deborah Walker  
Demand Management Coordinator

Capital Regional District Integrated Water Services  
479 Island Highway  
Victoria, BC V9B 1H7  
(250) 474-9600