

CAPITAL REGIONAL DISTRICT - INTEGRATED WATER SERVICES

Water Watch for June 12, 2016

Water Supply System Summary:

1. Useable Volume in Storage:

Reservoir	June 30 5 Year Ave		June 30/15		June 12/16		% Existing Full Storage
	ML	MIG	ML	MIG	ML	MIG	
Sooke	84,612	18,615	79,908	17,580	82,030	18,047	88.5%
Goldstream	8,615	1,895	7,692	1,692	7,839	1,725	79.8%
Total	93,227	20,510	87,600	19,272	89,870	19,771	87.6%

2. Average Daily Demand:

For the month of June	182.9 MLD	40.24 MIGD
For week ending June 12, 2016	183.6 MLD	40.39 MIGD
Max. day June 2016, to date:	213.9 MLD	47.06 MIGD

3. Average 5 Year Daily Demand for June

Average (2011 - 2015)	174.2 MLD ¹	38.32 MIGD ²
-----------------------	------------------------	-------------------------

¹MLD = Million Litres Per Day ²MIGD = Million Imperial Gallons Per Day

4. Rainfall June:

Average (1914 - 2015):	35.5 mm
Actual Rainfall to Date	10.1 (28% of monthly average)

5. Rainfall: Sep 1 - Jun 12

Average (1914 - 2015):	1564.1 mm
2015/2016	1781.8 (114% of average)

6. Water Conservation Action Required:

If each of us save a little, together we can save a lot.

Check our website at www.crd.bc.ca/water for more information.

If you require further information, please contact:

Ted Robbins, B.Sc., C.Tech
General Manager, CRD - Integrated Water Services
or

Deborah Walker
Demand Management Coordinator

Capital Regional District Integrated Water Services
479 Island Highway
Victoria, BC V9B 1H7
(250) 474-9600