

**CAPITAL REGIONAL DISTRICT - INTEGRATED WATER SERVICES**  
**Water Watch for June 16, 2019**

**Water Supply System Summary:****1. Useable Volume in Storage:**

Reservoir	June 30 5 Year Ave		June 30/18		June 16/19		% Existing Full Storage
	ML	MIG	ML	MIG	ML	MIG	
Sooke	82,159	18,075	82,102	18,062	84,027	18,486	90.6%
Goldstream	7,570	1,665	7,570	1,665	5,322	1,171	54.2%
Total	89,729	19,740	89,672	19,728	89,350	19,657	87.1%

**2. Average Daily Demand:**

For the month of June	185.0 MLD	40.71 MIGD
For week ending June 16, 2019	194.6 MLD	42.81 MIGD
Max. day June 2019, to date:	215.7 MLD	47.46 MIGD

**3. Average 5 Year Daily Demand for June**

Average (2014 - 2018)	182.1 MLD <sup>1</sup>	40.05 MIGD <sup>2</sup>
-----------------------	------------------------	-------------------------

<sup>1</sup>MLD = Million Litres Per Day      <sup>2</sup>MIGD = Million Imperial Gallons Per Day

**4. Rainfall June:**

Average (1914 - 2018):	35.4 mm
Actual Rainfall to Date	4.3 mm (12% of monthly average)

**5. Rainfall: Sep 1- Jun 16**

Average (1914 - 2018):	1,570.6 mm
2018 - 2019	1,441.1 mm (92% of average)

**6. Water Conservation Action Required:**

CRD's Stage 1 Water Conservation Bylaw is now in effect through to September 30, 2019.  
 Visit [www.crd.bc.ca/water](http://www.crd.bc.ca/water) for scheduling information.

If you require further information, please contact:

Ted Robbins, B.Sc., C.Tech  
 General Manager, CRD - Integrated Water Services  
 or  
 Glenn Harris, Ph D., RPBio  
 Senior Manager - Environmental Protection

Capital Regional District Integrated Water Services  
 479 Island Highway  
 Victoria, BC V9B 1H7  
 (250) 474-9600